

## Suitability of fire extinguishers:



- Powder
- Foam
- Water



Fires involving solid materials, mainly of an organic nature, which normally form flames and embers on burning

Powder extinguisher with ABC powder      Water and foam extinguisher



- Powder
- Foam
- CO<sub>2</sub>



Fires involving liquids or melting materials

Powder extinguisher with BC and ABC powder      Foam extinguisher      CO<sub>2</sub> extinguisher



- Powder



Fires involving gases (e.g. propane, butane etc.)

Powder extinguisher with BC and ABC powder



- Powder



Fires involving metals (e.g. magnesium, aluminum swarf)

Powder extinguisher with D powder



- Foam



Fires involving fat and oil, extinguisher marked orange

At least one fire extinguisher conformant with DIN EN 3 with at least 10 extinguishing agent units (EAUs) must be kept on hand at trade fair stands and event spaces larger than 100 m<sup>2</sup> during assembly and disassembly and during the event itself.

- The fire classes of fire extinguishers **have nothing** in common with the classification of building products to DIN 4102 and DIN EN 13501.
- The fire classes define **the suitability** of fire extinguishers for fires involving various materials, liquids or vapours that have caught fire.

## Explanation of official designation of fire extinguishers:

DIN EN 3	Current European standard
6	Weight/charge in kg
PG	Code letter: In this case ABC powder

## Table:

Designation	Extinguishing agent	Code letter
Water extinguisher	Water and aqueous solutions	W
Foam extinguisher	Foam	S
Powder extinguisher	ABC powder	PG
	BC powder	P
	D powder	PM
Carbon dioxide extinguisher	Carbon dioxide (CO <sub>2</sub> )	K

## Example of specified labeling to DIN EN 3:

**FEUERLÖSCHER**  
12 Kg ABC-Pulver  
43 A      183 B      C

---

1 Ventil voll aufdrehen

2 Löschpistole betätigen

---

**VORSICHT BEI ELEKTRISCHEN ANLAGEN. NUR BIS 1000 V; MINDESTABSTAND 1m**

Nach jeder Betätigung neu füllen!  
Löcher längstens alle 2 Jahre auf Einsatzbereitschaft überprüfen. Nur solche Lösch-Treibmittel und Ersatzteile verwenden, die mit dem anerkannten Muster übereinstimmen.

Löschmittel: 12 kg ABC      Nr. der Anerkennung:      DIN EN 3  
 Treibmittel: 280 g CO<sub>2</sub>      Typ:      G 12 R

---

Funktionsbereich: -20 °C bis +60 °C

---

HERSTELLER: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Only water extinguishers or foam extinguishers with an up-to-date test seal may be used. Powder extinguishers may only be used for demonstrations with combustible gases. Cleaning costs resulting from the use of powder extinguishers will be charged to the perpetrator. Generally, all fire extinguishers provided must have been tested by an accredited expert. This must be shown on the fire extinguisher itself by means of a valid test label or tag. All fire extinguishers must be placed in clearly visible and continuously accessible locations in such a way that they cannot topple over and must be labeled in accordance with ASR A1.3.